



Town of Garner

900 7th Avenue · Garner, North Carolina 27529
Phone (919) 772-4688 · Fax (919) 662-8874 · www.GarnerNC.gov



To: Jodi Miller, Town Manager

From: Forrest Jones, Public Works Director

cc: Matt Poole, Assistant Town Manger
David Beck, Finance Director

Date: April 23, 2026

Re: Emergency Repair for Lift Pump at Police Department and Fire Administration Building

On April 10, 2026 the alarm to the sewer lift pump that serves both the Garner Police Building and Garner Fire Administration Building activated alerting Public Works of an issue with the system. Public Works crews reached out to Full Circle Environmental LLC to pump out the holding tank and begin investigating the issue. Public Works investigation found that both pumps failed and needed replacement. Full Circle Environmental LLC was able to perform a patch to get the system back operational on very limited basis until the replacement pumps could be ordered and installed.

On April 11, 2026 the Town Manager authorized staff to move forward with this as an emergency repair per the Town's Policy due to the health and safety emergency this situation created. Therefore, the Town entered into an agreement with an authorized vendor to perform this repair at an estimated cost of \$26,350.00. Currently the repairs are scheduled to be completed by April 24, 2026.